



TOWER FOUNDATION

GENERAL NOTES

1. Base Designed for an allowable net soil pressure of 4000 PSF.
2. .98 Cubic yards concrete with 3000 PSI min.
3. Reinforcing steel-ASTM A-615 grade 40 deformed bars.
4. Min. Cover on all reinforcing steel is 3".
5. All forms must be removed from concrete before placing compacted backfill.
6. Vertical reinforcing steel may be place with an optional standard ACI 90 bend at bottom.